


ADDENDUM NO. 4
TO
CONTRACT DOCUMENTS
FOR
MAGNA WATER DISTRICT
WATER AND WASTEWATER TREATMENT UPGRADES

October 5th, 2018



October 5, 2018

This Addendum No. 4, pages 1 through 4 and attachments shall modify the Bid Documents for the Magna Water District Water and Wastewater Treatment Upgrades, and shall become part of the Contract Documents for this Project.

Bidders shall acknowledge receipt of Addenda by number in the space provided for that purpose on Document 00410 - Bid Form.

I. CONTRACT DOCUMENTS VOLUME 1: TECHNICAL SPECIFICATIONS DIVISIONS 00 TO 08

A. None.

II. CONTRACT DOCUMENTS VOLUME 2: TECHNICAL SPECIFICATIONS 09 TO 16 (partial)

A. Section 15052, 3.03 PIPING SCHEDULE, revise as follows:

CW	Cold Water	All	Copper	As specified	15281 - Copper Water Tube- Seamless, ASTM B88	Soldered	100 psig /HH	None	None		
DI	Deionized Water	All	PVC	SCH 80	15230 - Plastic Piping and Tubing	SW	125 psig /HH	None	None		
OF	Overflow	All	CPVC	SCH 80	15230 - Plastic Piping and Tubing	SW	125 psig /HH	None	None		
POL	Neat Polymer, Polymer Solution	All	CPVC	SCH 80	15230 - Plastic Piping and Tubing	SW	125 psig /HH	None	None		

III. CONTRACT DOCUMENTS VOLUME 3: TECHNICAL SPECIFICATIONS DIVISIONS 16
(Partial) to 17

A. None.

IV. CONTRACT DOCUMENTS VOLUME 4: TECHNICAL SPECIFICATIONS FOR C7
PIPELINE

A. None.

V. CONTRACT DOCUMENTS VOLUME 5: DRAWINGS

A. Sheet 20M01, revise as follows:

1. Adjacent to Keynote 24, revise callout ' 2" PN' to indicate ' **2" PVC hose**'
2. Keynote 7, revise as follows ' **Simplex Basket Strainer with Sch 80 PVC body, 3" Inlet and 3" Outlet true union connections with PVC screen comprised of 1/32" perforations, Hayward Model SB1200STE, or equal per Specification 15125** '.

B. Sheet 60M02, revise as follows:

1. Below the callout for 4" V, revise callout ' 4"FA' to indicate ' **3" FA** '.

C. Sheet C7-03:

1. Detail A, Existing Perimeter Drain, revise callout for 8" perforated pipe ' 8" ϕ perforated polyethylene drain pipe **N-12 by Advanced Drainage Systems, or equal**"
2. Detail B, Existing Perimeter Drain Clean Out, revise callout for 8" perforated pipe ' 8" ϕ perforated polyethylene drain pipe **N-12 by Advanced Drainage Systems, or equal**"

VI. CONTRACT DOCUMENTS VOLUME 6: PRE-PURCHASED AERATION EQUIPMENT
AND PRE-NEGOTIATED PLC AND INTEGRATION

A. None.


VII. ATTACHED PAGES, SECTIONS, DETAILS, AND DRAWINGS

A. None.

This Addendum No. 4 and attachments, shall become part of the Contract and all provisions of the Contract shall apply thereto. The time provided for completion of the Contract is not changed.

Bidders shall acknowledge receipt of all Addenda by number in the space provided in the Proposal.

CAROLLO ENGINEERS, P.C.

A handwritten signature in black ink, appearing to read "John B. Richardson". The signature is fluid and cursive, with a large initial "J" and "R".

John B. Richardson, P.E.
PE NO. 295556